

Burlington WA Corporate Office

Bellingham WA Microbiology

Portland OR Microbiology/Chemistry

1620 S Walnut St - 98233 800.755.9295 • 360.757.1400 360.671.0688

805 W Orchard Dr Ste 4 - 98225 9150 SW Pioneer Ct Ste W- 97070

Page 1 of 1

Project: Bacteria

Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: Beverly Beach Improvement Club Reference Number: 14-05527

PO BOX 12

Freeland, WA 98249

System Name: BEVERLY BEACH IMPROVEMENT CLUB Repeat Sample Number:

System ID Number: 061475 Lab Number: 164-13579 DOH Source Number: 00 - Distribution Sample (Bacteria) Field ID:

Sample Type: D - Drinking Water Date Collected: 4/1/14 09:00

Sample Purpose: C - Compliance Date Received: 4/1/14

Sample Location: X-1 Hose Bib Date Analyzed: 4/02/14 11:25

County: Island Report Date: 4/2/14 Sampled By: Joe Waldrup Comment: Cl2: 0.21

Sampler Phone: 360-625-2457 Peer Review:

OOH#	PARAMETER	RESULT	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent	per 100mL	jmm	SM9223 B	m_140401	
3	E. COLI	Absent	per 100mL		SM9223 B	m_140401	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

Island Co: http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm

San Juan Co: http://www.sanjuanco.com/health/ehswater.aspx Skagit Co: http://www.skagitcounty.net/drinkingwater or 360-336-9380

Snohomish Co: <u>425-339-5250</u>

Whatcom Co: http://www.co.whatcom.wa.us/health/environmental/drinking water/index.jsp

WSDOH: http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm

If the result is Unsatisfactory a repeat sample is required for Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample. If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.

email: jkwaldrup2@comcast.net