



Burlington WA A Corporate Office 1620 S Walnut St - 98233 800.755.9295 • 360.757.1400
 Bellingham WA B Microbiology 805 W Orchard Dr Ste 4 - 98225 360.671.0688
 Portland OR C Microbiology/Chemistry 9150 SW Pioneer Ct Ste W- 97070 503.682.7802



DISINFECTION BY-PRODUCT COMPOUNDS REPORT

Client Name: Beverly Beach Improvement Club
 PO BOX 12
 Freeland, WA 98249

Reference Number: 14-09968
 Project: DBP

System Name: BEVERLY BEACH IMPROVEMENT CLUB
 System ID Number: 06147
 DOH Source Number: 92 - Distribution Sample
 Multiple Sources:
 Sample Type: A - After treatment
 Sample Purpose: C - Compliance
 Sample Location: X-1 Hose Bibb
 County: Island
 Sampled By: Joe Waldrup
 Sampler Phone: 360-675-2457

Field ID: DBP
 Lab Number: 046-23919
 Date Collected: 6/3/14 08:00
 Date Extracted: 552_140611
 Date Analyzed: 06/11/14
 Report Date: 6/13/14
 Analyst: PMS
 Released By:

EPA Method 552.3 For State Drinking Water Compliance

DOH#	COMPOUNDS	RESULTS	UNITS	SRL	Trigger	MCL	COMMENT
Halo-Acetic Acids							
411	MONOCHLOROACETIC ACID	ND	ug/L	2			
412	DICHLOROACETIC ACID	ND	ug/L	1			
413	TRICHLOROACETIC ACID	ND	ug/L	1			
414	MONOBROMOACETIC ACID	ND	ug/L	1			
415	DIBROMOACETIC ACID	ND	ug/L	1			
416	HAA(5)	ND	ug/L	1	45	60	Field DUP: ND
Other							
417	BROMOCHLOROACETIC ACID	ND	ug/L	1			

NOTES:
 If a compound is detected > or = to the State Reporting Level, SRL, specified increased monitoring frequencies may occur per DOH.
 MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.
 Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.
 ND (Not Detected): indicates that the parameter was not detected above the State Reporting Limit (SRL).
 An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.
 Lab - Indicates where parameter was analyzed. See header address for lab code.
 These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.
 If you have any questions concerning this report contact Lawrence Henderson at the above phone number.
 FORM: cODBP.rpt