



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946



FL NELAP E871040

Page 1 of 1

## DISINFECTION BY-PRODUCT COMPOUNDS REPORT

Client Name: **Beverly Beach Improvement Club**  
**PO BOX 12**  
**Freeland, WA 98249**

Reference Number: **14-16926**  
 Project: **DBP**

System Name: **BEVERLY BEACH IMPROVEMENT CLUB**  
 System ID Number: **06147**  
 DOH Source Number: **92 - Distribution Sample**  
 Multiple Sources:  
 Sample Type: **A - After treatment**  
 Sample Purpose: **C - Compliance**  
 Sample Location: **X-1 Hose Bib**  
 County: **Island**  
 Sampled By: **Joe Waldrup**  
 Sampler Phone:

Field ID:  
 Lab Number: **046-38901**  
 Date Collected: **9/2/14 09:00**  
 Batch: **552\_140905**  
 Date Analyzed: **09/05/14**  
 Report Date: **9/10/14**  
 Analyst: **PMS**  
 Approved By: **mcs,pdm**  
 Authorized By:

*Patrick Miller*  
 Patrick Miller, MS  
 QA Officer

DOH#	COMPOUNDS	RESULTS	UNITS	SRL	Trigger	MCL	METHOD	Lab	COMMENT
	<b>Halo-Acetic Acids</b>								
411	MONOCHLOROACETIC ACID	<b>ND</b>	ug/L	2			552.3	A	
412	DICHLOROACETIC ACID	<b>3.0</b>	ug/L	1			552.3	A	
413	TRICHLOROACETIC ACID	<b>5.5</b>	ug/L	1			552.3	A	
414	MONOBROMOACETIC ACID	<b>ND</b>	ug/L	1			552.3	A	
415	DIBROMOACETIC ACID	<b>ND</b>	ug/L	1			552.3	A	
416	HAA(5)	<b>8.5</b>	ug/L	1	45	60	552.3	A	
	<b>Other</b>								
417	BROMOCHLOROACETIC ACID	<b>ND</b>	ug/L	1			552.3	A	
	<b>EPA Regulated - Under Trihalomethanes Program</b>								
27	CHLOROFORM	<b>30.5</b>	ug/L	0.5			524.2	A	
28	BROMODICHLOROMETHANE	<b>7.6</b>	ug/L	0.5			524.2	A	
29	CHLORODIBROMOMETHANE	<b>1.4</b>	ug/L	0.5			524.2	A	
30	BROMOFORM	<b>ND</b>	ug/L	0.5			524.2	A	
31	TOTAL TRIHALOMETHANE	<b>39.5</b>	ug/L		60	80	524.2	A	

**NOTES:**  
 If a compound is detected > or = to the State Reporting Level, SRL, specified increased monitoring frequencies may occur per DOH.  
 MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.  
 Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.  
 ND (Not Detected); indicates that the parameter was not detected above the State Reporting Limit (SRL).  
 An \* in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.  
 Lab - Indicates where parameter was analyzed. See header address for lab code.  
**These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.**  
 If you have any questions concerning this report contact Patrick Miller, MS, QA Officer, at the toll-free phone number above.  
 FORM: cODBP.rpt