

Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400	
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212	
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802	
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946	



Page 1 of 1

Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: Beverly Beach Improvement Club Reference Number: 17-18949

PO BOX 12

Freeland, WA 98249

System Name: BEVERLY BEACH IMPROVEMENT CLUB

System ID Number: 061475

DOH Source Number: 00 - Distribution Sample (Bacteria)

Sample Type: D - Drinking Water
Sample Purpose: C - Compliance
Sample Location: X - 3 Hose Bib

County: Island
Sampled By: Joe Waldrup
Sampler Phone: 360-625-2457

Repeat Sample Number:

Lab Number: 164-42791

Project: Bacteria

Field ID: 1

Date Collected: 8/1/17 09:10

Date Received: 8/1/17

Date Set: 8/1/17 18:22

Date Analyzed: 8/2/17 12:51

Report Date: 8/4/17

Comment: Cl2: 0.50

Approved By: ckk,jma

Authorized by:

Ceann K Knox Microbiologist/QA Officer

						viioi obiologica	
DOH#	PARAMETER	RESULT	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent	per 100mL	sms	SM9223 B	m_170801b	
3	E. COLI	Absent	per 100mL		SM9223 B	m_170801b	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

Island Co: http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm

San Juan Co: http://www.sanjuanco.com/health/ehswater.aspx

Skagit Co: http://www.skagitcounty.net/drinkingwater_ or 360-336-9380

Snohomish Co: 425-339-5250

Whatcom Co: http://www.co.whatcom.wa.us/health/environmental/drinking water/index.jsp

WSDOH: http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm

NOTES

If the result is Unsatisfactory a repeat sample is required for Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample. If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.