



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946



FL NELAP E871040

## INORGANIC COMPOUNDS (IOC) REPORT

Client Name: **Beverly Beach Improvement Club**  
 PO BOX 12  
 Freeland, WA 98249

Reference Number: **17-23967**  
 Project: **Conductivity**

System Name: **BEVERLY BEACH IMPROVEMENT CLUB**  
 System ID Number: **06147**  
 DOH Source Number: **02**  
 Multiple Sources:  
 Sample Type: **B - Before treatment**  
 Sample Purpose: **C - Compliance**  
 Sample Location: **Well Head**  
 County: **ISLAND**

Sample Number:  
 Lab Number: **046-52786**  
 Collect Date: **9/7/17 09:00**  
 Date Received: **9/7/17**  
 Report Date: **9/21/17**  
 Sampled By: **Joe Waldrup**  
 Sampler Phone: **360-625-2457**  
 Approved by: **hkl**  
 Authorized by:

*J. Henderson*  
 Lawrence J Henderson, PhD  
 Director of Laboratories, Vice President

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
16	<b>Other</b> ELECTRICAL CONDUCTIVITY	<b>354</b>	uS/cm	10		700	lrs	SM2510 B	a	09/20/17	

**NOTES:**

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).  
 MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.  
 Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.  
 ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).  
 An \* in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.  
 If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number above.