

LEAD & COPPER RULE REPORT

Client Name: Beverly Beach Improvement Club
 PO BOX 12
 Freeland, WA 98249

Reference Number: 17-24023
 Project: Lead & Copper

System Name: BEVERLY BEACH IMPROVEMENT CLUB
 System ID Number: 06147
 DOH Source Number: 01
 Multiple Sources:
 Sample Type: A - After treatment
 Sample Purpose: C - Compliance
 County: ISLAND

Analyst: bj
 Date Received: 9/7/2017
 Report Date: 9/14/2017
 Approved By: anp
 Authorized By:

[Signature]
 Lawrence J Henderson, PhD
 Director of Laboratories, Vice President

Lab Number	Date Collected	Site / Location	PRM #	Analyte Name	Result	Units	AL	SRL	METHOD	Lab	Analyzed	Comments
046-52898	9/7/2017	- 4244 Beach, Freeland WA 98249 <i>Summits</i>	9	LEAD	0.005	mg/L	0.015	0.001	200.8	a	9/13/17	
			23	COPPER	0.519	mg/L	1.3	0.005	200.8	a	9/13/17	
046-52899	9/7/2017	- 4216 Beach Drive, Freeland WA 98249 <i>Demotat</i>	9	LEAD	0.002	mg/L	0.015	0.001	200.8	a	9/13/17	
			23	COPPER	0.133	mg/L	1.3	0.005	200.8	a	9/13/17	
046-52900	9/7/2017	- 4174 Beach Drive <i>Norman</i>	9	LEAD	0.001	mg/L	0.015	0.001	200.8	a	9/13/17	
			23	COPPER	0.007	mg/L	1.3	0.005	200.8	a	9/13/17	
046-52901	9/7/2017	- #4 <i>4170 Beach Dr Barnes</i>	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	9/13/17	
			23	COPPER	0.028	mg/L	1.3	0.005	200.8	a	9/13/17	
046-52902	9/7/2017	- 1842 Foliage St, Freeland, WA <i>Chantwood</i>	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	9/13/17	
			23	COPPER	0.067	mg/L	1.3	0.005	200.8	a	9/13/17	

NOTES:

State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH)
 AL: Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Specified Reporting Limit (SRL).

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.
 If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number