



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946



Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: **Beverly Beach Improvement Club**
PO BOX 12
Freeland, WA 98249

Reference Number: **17-27598**
 Project: **Bacteria**

System Name: **BEVERLY BEACH IMPROVEMENT CLUB**
 System ID Number: **061475**
 DOH Source Number: **00 - Distribution Sample (Bacteria)**
 Sample Type: **D - Drinking Water**
 Sample Purpose: **C - Compliance**
 Sample Location: **X - 2 Hose Bib**
 County: **Island**
 Sampled By: **Joe Waldrup**
 Sampler Phone: **360-625-2457**

Repeat Sample Number:
 Lab Number: **164-60239**
 Field ID: **1**
 Date Collected: **10/3/17 08:10**
 Date Received: **10/3/17**
 Date Set: **10/3/17 17:45**
 Date Analyzed: **10/4/17 12:17**
 Report Date: **10/5/17**
 Comment: **Cl2: 0.46**
 Approved By: **clh**

Authorized by:


 Cynthia L. Hansen
 Lab Manager

DOH#	PARAMETER	RESULT	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent	per 100mL	jfh	SM9223 B	m_171003b	
3	E. COLI	Absent	per 100mL		SM9223 B	m_171003b	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: http://www.skagitcounty.net/drinkingwater_ or 360-336-9380
- Snohomish Co: [425-339-5250](http://www.snohomishcountywa.gov/ehp/dw/Programs/coliform.htm)
- Whatcom Co: http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

NOTES:
 If the result is Unsatisfactory a repeat sample is required for Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.
 If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.