



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946



Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: WWSVC - Beverly Beach Improvement Club
14263 Calhoun Road
Mount Vernon, WA 98273

Reference Number: 19-23811
Project: BBIC Well

System Name: BEVERLY BEACH IMPROVEMENT CLUB
System ID Number: 061475
DOH Source Number: 00 - Distribution Sample (Bacteria)
Sample Type: D - Drinking Water
Sample Purpose: Investigative or Other
Sample Location: S02 Raw Sample Tap
County: Island
Sampled By: Dylan Herndon
Sampler Phone:

Repeat Sample Number:
Lab Number: 164-46534
Field ID: 1040188577
Date Collected: 6/26/19 15:15
Date Received: 6/27/19
Date Set: 6/27/19 17:37
Date Analyzed: 6/28/19 11:59
Report Date: 6/28/19
Comment:
Approved By: jfh,jln

Authorized by:

Cynthia L. Hansen
Microbiologist/Office Manager

DOH#	PARAMETER	RESULT	Qualifier	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent		per 100mL	rml	SM9223 B	m_190627b	
3	E. COLI	Absent		per 100mL		SM9223 B	m_190627b	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: http://www.skagitcounty.net/drinkingwater_ or 360-336-9380
- Snohomish Co: 425-339-5250
- Whatcom Co: http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

NOTES:
If the result is Unsatisfactory a repeat sample is required for Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.
If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.
*If data qualifiers are present, see accompanying Qualifier Definition report.