



Burlington WA  
Corporate Office

Bellingham WA  
Microbiology

Portland OR  
Microbiology/Chemistry

1620 S Walnut St - 98233  
800.755.9295 • 360.757.1400

805 Orchard Dr Ste 4 - 98225  
360.671.0688

9150 SW Pioneer Ct Ste W- 97070  
503.682.7802

## Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: Beverly Beach Improvement Club  
PO BOX 12  
Freeland, WA 98249

Reference Number: 10-19415  
Project: Bacteria

System Name: BEVERLY BEACH IMPROVEMENT CLUB  
System ID 061475

Repeat Sample Number:  
Lab Number: 164-43501

DOH Source Number: 00 - Distribution Sample (Bacteria)

Field ID:

Sample Type: D - Drinking Water

Date Collected: 12/28/10 13:15

Sample Purpose: C - Compliance

Date Received: 12/28/10

Sample Location: 4110 Beach Dr. Kitchen Tap

Date Analyzed: 12/29/10 11:40

County: Island

Report Date: 12/29/10

Sampled By: S Wicklund

Comment: CI2:0.4

Sampler Phone: 360-730-1354

Peer Review:

DOH#	PARAMETER	RESULT	UNITS	Analyst	METHOD	COMMENT
1	TOTAL COLIFORM	<b>Satisfactory, Coliforms Absent</b>	per 100mL	sm	SM9223 B	
3	E. COLI	<b>Absent</b>	per 100mL		SM9223 B	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>

San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>

Skagit Co: <http://www.skagitcounty.net/drinkingwater> or 360-336-9380

Snohomish Co: 425-339-5250

Whatcom Co: [http://www.co.whatcom.wa.us/health/environmental/drinking\\_water/index.jsp](http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp)

WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

**NOTES:**

If the result is Unsatisfactory a repeat sample is required for Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.  
If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.