



Burlington WA
Corporate Office

1620 S Walnut St - 98233
800.755.9295 • 360.757.1400

Bellingham WA
Microbiology

805 Orchard Dr Ste 4 - 98225
360.671.0688

Portland OR
Microbiology/Chemistry

9150 SW Pioneer Ct Ste W- 97070
503.682.7802

Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: Beverly Beach Improvement Club
PO BOX 12
Freeland, WA 98249

System Name: BEVERLY BEACH IMPROVEMENT CLUB
System ID 061475

DOH Source Number: 00 - Distribution Sample (Bacteria)
Sample Type: D - Drinking Water
Sample Purpose: C - Compliance
Sample Location: 4022 Alder Bathroom Tap
County: Island
Sampled By: S Wicklund
Sampler Phone: 360-730-1354

Reference Number: 11-01201
Project: Bacteria

Repeat Sample Number:
Lab Number: 164-02780
Field ID:
Date Collected: 1/25/11 11:45
Date Received: 1/25/11
Date Analyzed: 1/26/11 11:45
Report Date: 1/26/11
Comment: CI2:0.4
Peer Review:

DOH#	PARAMETER	RESULT	UNITS	Analyst	METHOD	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent	per 100mL	sm	SM9223 B	
3	E. COLI	Absent	per 100mL		SM9223 B	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: <http://www.skagitcounty.net/drinkingwater> or 360-336-9380
- Snohomish Co: 425-339-5250
- Whatcom Co: http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

NOTES:

If the result is Unsatisfactory a repeat sample is required for Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample. If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.