



Burlington WA      Bellingham WA      Portland OR  
 Corporate Office      Microbiology      Microbiology/Chemistry  
 1620 S Walnut St - 98233      805 W Orchard Dr Ste 4 - 98225      9150 SW Pioneer Ct Ste W- 97070  
 800.755.9295 • 360.757.1400      360.671.0688      503.682.7802

MAR 31 2011

Washington State Department of Health  
 WATER BACTERIOLOGICAL ANALYSIS

Client Name: Beverly Beach Improvement Club  
 PO BOX 12  
 Freeland, WA 98249

Reference Number: 11-04159  
 Project: Bacteria

System Name: BEVERLY BEACH IMPROVEMENT CLUB  
 System ID Number: 061475  
 DOH Source Number: 00 - Distribution Sample (Bacteria)  
 Sample Type: D - Drinking Water  
 Sample Purpose: C - Compliance  
 Sample Location: 4110 Beach Dr. Utility Tap  
 County: Island  
 Sampled By: S Wicklund  
 Sampler Phone: 360-730-1354

Repeat Sample Number:  
 Lab Number: 164-09304  
 Field ID:  
 Date Collected: 3/24/11 11:30  
 Date Received: 3/24/11  
 Date Analyzed: 3/25/11 11:55  
 Report Date: 3/25/11  
 Comment: CI2:0.4  
 Peer Review:

DOH#	PARAMETER	RESULT	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	<b>Satisfactory, Coliforms Absent</b>	per 100mL	slm	SM9223 B	m_110324	
3	E. COLI	<b>Absent</b>	per 100mL		SM9223 B	m_110324	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: <http://www.skagitcounty.net/drinkingwater> or 360-336-9380
- Snohomish Co: 425-339-5250
- Whatcom Co: [http://www.co.whatcom.wa.us/health/environmental/drinking\\_water/index.jsp](http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp)
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

NOTES:

If the result is Unsatisfactory a repeat sample is required for Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.  
 If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.