



Board of Directors  
**Beverly Beach Improvement Club**  
 Monthly Report of System Operation  
**Month:** December 2017

For the month of December the Beverly Beach Improvement Club water system ran well. Monthly bacterial results met state DOH requirements.

**Production**

<i>Based on Daily Log Sheets from 12/01/17 to 12/29/17</i>	<b>Current Month 29 Days</b>	<b>Last Month 29 Days</b>	<b>Difference</b>	<b>Last Year -- Days</b>	<b>Difference</b>
<b>Total Production</b>	144,460	186,630		N/A	
<b>Daily Avg.</b>	4,981	6,436	-23%	N/A	N/A
<b>GPD/Home - 53</b>	94	121	-22%	N/A	N/A

**Miscellaneous**

- 12/06/17- Collected compliance bacteria sample at 4010 Maple.
- 12/08/17- Installed pre-filter sample tap.
- 12/13/17- Post filter CL2 injection pump offline. Pre-filter dosage is meeting and exceeding chlorine demand providing free chlorine residual in reservoir.
- 12/15/17- Flushed North End; 6,000 gallons of water to waste.